
WIRING DIAGRAM

WIRING DIAGRAM

Model: MHWW-09-H-1 & MHWW-12-H-1



- NOTES:
 - 1. 208/230V 24Vac TRANSFORMER
 - 2. WIRELESS REMOTE INCLUDES A WALL MOUNTING BRACKET
 - 3. JUMPER MUST BE FIELD INSTALLED FOR 2-PIPE HEAT/COOL OPERATION
 - 4. 4-PIPE WIRING AND VALVE CONFIGURATION
 - 5. 2-PIPE WIRING AND VALVE CONFIGURATION
 - 6. WIRED REMOTE UNIT, OPTIONAL
 - 7. THE FIELD WIRING CONDUCTOR OF HIGH AND LOW VOLTAGE CIRCUIT SHALL BE SEPARATELY FIXED FIRMLY BY EACH CLAMP.
 - 8. ALL WIRING SHALL BE DONE ACCORDING TO NATIONAL AND LOCAL CODE REQUIREMENTS.
 - A LINE OF SIGHT SERVICE DISCONNECT MUST BE PROVIDED AS A MEANS TO TURN OFF POWER FOR SERVICING.

 $\overline{10}$

P/N: PP090215



MHWW-12-H-1 Dimensional Drawing

